

DATE: 18 únor 2019

DESIGNER:

PROJECT No: hlavní komunikace M4 - stožáry distribuční sítě obce u nospod

PROJECT NAME: Juřinka



Valašské Meziříčí

svítidlo BARA E 2B2.60-4070-ME
nastavení T3160QPNA


PREPARED BY:

Radek Pechman
Tresnova 520
Stenovice
Czech republic

e-mail: info@pechman.cz
web: www.pechman.cz

Roadway Report Summary

Layout



Road Data

Calculation Grid	EN13201 Luminance
Width (m)	5.00
No. of Lanes	2
Road Surface	R3
Q0	0.07
Lane Width (m)	2.50
Rei Width (m)	2.50

Main Lighting

Column Data

Configuration	Single Sided Right
Spacing (m)	35.00
Height (m)	8.00
Tilt (deg)	0.00
Setback (m)	2.00
Outreach (m)	1.50
Overhang (m)	-0.50

Luminaire Data

Supplier	PECHMAN
Type	BARA E XXX.60-4070-ME
Lamp(s)	measured luminous flux of whole luminaire
LampFlux(klm)/Colour	7.03 4062/70
File Name	BARA E XXX.60-4070-ME_T3160QPNA.LDT
Maintenance Factor	0.80
Lum. Int. Class	None


Results

Main

Complies with M4


Lavmin	0.76 (1)
Lmin	0.49 (1)
Lmax	1.09 (2)
U0min	0.64 (1)
Ulmin	0.72 (2)
TI(%)	11.94 (1)
Rei	0.81

Number in brackets is the Observer Lane for Result shown.




Polar Diagram

Main Luminaire BARA E XXX.60-4070-ME



Luminance (cd/m²)

Observer in Lane 1



Main Results


Observers in all Lanes

Lavmin	0.76 (1)
Lmin	0.49 (1)
Lmax	1.09 (2)
U0min	0.64 (1)
Ulmin	0.72 (2)
Tlmax(%)	11.94 (1)
Rei	0.81

Number in brackets is the
Observer Lane for Result shown.

Luminance (cd/m²)

Observer in Lane 1




Main Results

Observer in Lane 1

Lav	0.76
Lmin	0.49
Lmax	1.07
U0	0.64
UI	0.77
TI(%)	11.94

Luminance (cd/m²)

Observer in Lane 1



DATE: 18 únor 2019


DESIGNER:

PROJECT No: hlavní komunikace PRŮJEKT JEDNOLISTOVÝHO STROJNÍHO KASÍŘE 6c u hospody




Luminance (cd/m²)

Observer in Lane 1



Luminance (cd/m²)

Observer in Lane 2



Main Results

Observer in Lane 2

Lav	0.83
Lmin	0.54
Lmax	1.09
U0	0.65
UI	0.72
TI(%)	11.81

DATE: 18 únor 2019


DESIGNER:

PROJECT No: hlavní komunikace PROJEKT NÁMĚSTÍ OBČANSKÉHO DOMU
PROJECT NAME: Návrh osvětlení střešní plochy 6c u hospody



Luminance (cd/m²)

Observer in Lane 2



Luminance (cd/m²)

Observer in Lane 2

